



**PRE-MANUFACTURED PRESS BOX
MANUFACTURED BY WHITLEY MANUFACTURING**

FACTORY: MBI
BUILDING: 30'X8' 1-STORY W/ CAMERA DECK
UNITS: (1) 30'X8' BOX SIZE MODULE (MOD TO SHIP AS A 10' WIDE)
CODE: 2015 IBC/ 2015 IECC

FRAME:

TYPE: PERIMETER
MAIN BEAM: C10X15.3#/FT
X-MEMBER: 8" 18 GAUGE OR AS REQ'D. AT 16" O.C.
HITCH: NONE
AXLES: NONE
MISC: INSTALL (6) PLATES ON FRAMES WITH WELDED NUTS FOR LIFTING EYES
MISC: SHIPLOOSE (6) BOLT-ON FRAME MOUNT LIFTING EYES

FLOOR:

BTM BOARD: 1/2" PRESSURE TREATED PLYWOOD
MISC: BTM BOARD PAINTED BLACK
INSULATION: R-30 KRAFT FACED IN FRAME
JOISTS: NONE DECKING SCREWED DIRECTLY TO CROSS MEMBERS
DECKING: 3/4" T & G U.L. PLYWOOD 5 PLY 5 LAYER STURDI-FLOOR OR EQUAL
COVERING: 1/8" VINYL COMP. TILE
DUCT: N/A
BASE TRIM: 4" VINYL COVE BASE

EXTERIOR WALLS

STUDS: 2"X6" STUD GRADE @ 16"O.C.
(115 MPH WIND LOAD DESIGN)
IBC FRAMING
WALL HGT: 8'-0" FINISH CEILING HGT TO TOP OF T-GRID
COVERING: 5/8" VINYL COVERED GYPSUM GROUP II
MISC: VINYL BATTENS TO MATCH WALL COVERING AT GYP SEAMS
COLOR: TO BE SELECTED FROM MANUFACTURERS STD COLORS
SHEATHING: 1/2" CDX PLYWOOD
SHEATHING: AIR INFITRATION BARRIER
INSULATION: R-21 KRAFT FACED
SIDING: 29 GAUGE COMMERCIAL STEEL
TRIM: STEEL
SKIRTING: NONE (RUN SHEATHING TO THE BOTTOM OF FRAME AND SHIPLOOSE
SIDING TO COVER THE FRAME FOR INSTALLATION AT SITE AT LIFTING
EYE LOCATIONS.)

INTERIOR WALLS

8 L.F.: 8'H VINYL COVERED GYPSUM 5/8" (2X4 STUDS)
MISC: VINYL BATTENS TO MATCH WALL COVERING AT GYP SEAMS



COLOR: TO BE SELECTED FROM MANUFACTURERS STD COLORS
CHASE WALLS PARTIAL WIDTH OF MODULE TO ENCLOSE ELECTRICAL PANELS

ROOF:

RAFTERS: 2X12 S.P.F.#2 AT 16" O.C.
ONE-WAY ROOF SLOPE TO REAR W/ 100# ROOF LIVE LOAD

CEILING: FISSURED SUSPENDED CEILING (24X48 TILE)
FINISH CEILING HEIGHT OF 8'-0" TO TOP OF T-GRID

TRUE CEILING CLASS "A" VAPOR BARRIER

INSULATION R-42 KRAFT FACED

SHEATHING 3/4" T&G CDX PLYWOOD

SHEATHING: 1/4" DENS DECK

ROOFING: .060 DEC-TEC REINFORCED VINYL SHEET GOODS
(MODULE **DOES** HAVE A ROOF DESIGNED FOR FOOT TRAFFIC)

OVERHANG: 15-1/2" ON FRONT 30' EXTERIOR WALL
AND 6" ON REAR 30' EXTERIOR WALL AND END WALLS
W/ VENTED 29 GA. STEEL SOFFIT AND FACIA
(82) LF TOTAL OVERHANG

MISC: 1/2" DIAMETER CARRIAGE BOLTS STUB THRU PERIMETER FASCIA @
48" O.C. W/ BLOCKING AS REQUIRED FOR SITE INSTALLED RAILING BY
BLEACHERS INTERNATIONAL. EACH BOLT TO HAVE 1/2"X4"X4" NEOPRENE
GASKET, WASHERS, AND NUT

MISC: GUTTERS AND DOWN SPOUTS BY OTHERS @ SITE

MISC: (2) FASCIA MOUNTED BOXES AT EACH OF THE 4 CORNERS. THE DATA BOX
WOULD HAVE A CONDUIT STUBBED TO THE CEILING CAVITY WITH PULL
WIRE AND A RAILING MOUNTED BOX WITH FLEXIBLE CONDUIT FOR
MOUNTING TO THE RAILING (WIRING AND DEVICES FOR THE DATA ARE
BY OTHERS).
A DUPLEX RECEPTACLE W/ BOX TO MOUNT ON THE RAILING W/ A
FLEXIBLE WIRING CONDUIT TO BE RAN TO THE PRE-WIRED FASCIA BOX
FOR THE (4) RECEPTACLES

DOORS:

EXT. DOOR: 36X80 18 GAUGE COMMERCIAL STL. WITH STL.JAMB (OUTSWING DOORS)
5"X20" TEMPERED INSULATED VISION PANEL
WITH STD. GRADE 2 LEVER LOCKSET (WITH KEYED CORE)
WITH STD. GRADE 2 CLOSER
W/ COMPRESSION TYPE WEATHER STRIPPING
QTY OF (2)

INT DOOR: 36X80 SOLID CORE WOOD W/ KNOCK DOWN STEEL FRAME
(PREFINISHED DOOR WITH TIMELY PAINTED FRAME)
WITH LEVER (GRADE II) (PASSAGE SET)
QTY OF (1)

WINDOWS:

SIZE: 48"H VINYL HORIZONTAL SLIDING (SILVERLINE BY ANDERSON)
(3-SASH WINDOWS WITH CENTER FIXED AND END SLIDERS)
WHITE VINYL

GLAZING: 3/4" INSULATED CLEAR (LOW "E") TEMPERED SAFETY GLASS

INT. TRIM: PRE-PAINTED



MISC.: WITH SCREENS
BLINDS: NONE
QTY OF (2) 84"WX48"H AND (2) 72"WX48"H 3-SASH WINDOWS

ELECTRICAL:

LOADCENTER: 120/240 V. 1-PHASE 60 HZ, 3-WIRE (SQUARE "D" OR EQUAL)
LOAD CENTER TYPE PANELS AND SNAP-IN TYPE BREAKERS
100 AMP MAIN
QTY OF (1)

WIRING: CONDUIT (#12 MIN WIRE SIZE) - TYPE THHN

INT. LIGHTS: 24"X48" (2) TUBE FLUOR. (LAY-IN)
(RECESSED)
QTY OF (4)

MISC: LIGHTS TO HAVE ELECTRONIC BALLAST AND T8 BULBS
MISC: LIGHTS TO HAVE 1/2" X 1/2" PARABOLIC DIFFUSERS
EXT. LIGHTS 60 WATT
QTY OF (2)

EGRESS LIGHT EXIT/EMERGENCY LIGHT WITH BATTERY
PACK AND REMOTE HEAD
QTY OF (2)
(EXTERIOR LIGHTS AND REMOTE HEADS SHIPPED LOOSE)

RECEPTS: 125 VOLT 20 AMP
RECEPTS: EXTERIOR RECEPT (GFI PROTECTED)
RECEPTS: WIRE MOLD 5400 SERIES SURFACE MOUNTED NON-METALLIC DUAL
CHANNEL RACEWAY W/ 120V DUPLEX RECEPTS AT 48" O.C. IN LINE
VOLTAGE CHANNEL AND BLANK COVERS 4' O.C. IN LOW VOLTAGE
CHANNEL. MOUNTED UNDER COUNTERTOP W/ 3/4" EMT STUBBED THRU
FLOOR
QTY OF (30) LF WIRE MOLD

SWITCHES: 110 VOLT OCCUPANCY SENSOR TYPE

PLUMBING:

PLUMBING: NONE

H.V.A.C.

HEAT/COOL: THRU WALL PTAC W/ 9,000 BTU COOL WITH 240/208 3.45 KW ELECTRIC
HEAT
STRIP, 20A CORD, AND INTEGRAL THERMOSTAT
QTY OF (2)

DUCTS: NONE

THERMOSTAT: BUILT-IN THE UNITS

FURNISHINGS:

SCORER'S TBL: 18" DEEP W/ .060 HPL OVER SUBSTRATE
AND 1-1/2" X 1 1/2" FRONT DROP EDGE
QTY OF (30) LF COUNTER TOP
W/ WHITE STEEL ANGLE BRACES AND GROMMETTES

MISC: BILCO NB-50 30"X54" ALUMINUM ROOF HATCH
QTY OF (1)

MISC.: ALACO MODEL 370 OR EQUAL ALUMINUM
70-DEGREE ROOF ACCESS SHIPS LADDER



QTY OF (1)

NOTES:

USE GROUP ASSEMBLY
VB COMBUSTIBLE WOOD CONSTRUCTION (UNPROTECTED)
OCCUPANT LOAD OF (16)
MIN FIRE SEPARATION OF 11'
(PROTECTED OPENINGS , IF REQUIRED ARE TO BE BY OTHERS)
HANDICAPPED RESTROOM FACILITIES MUST BE
AVAILABLE AT THE SITE AND WITH-IN
A REASONABLE PROXIMITY OF THE SITE
MANUFACTURERS LIMITED WARRANTY IS FOR 1
YEAR FROM THE DATE OF THE MANUFACTURERS
COMPLETION DATE ONLY.
WHITLEY MFG. IS NOT RESPONSIBLE FOR LOCAL CODES.

STRUCTURAL SUPPORT BELOW PRESS BOX AS REQUIRED TO BE BY
BLEACHERS INTERNATIONAL @ SITE. WHITLEY MFG. TO PROVIDE
STANDARD BLOCKING
POINT DETAILS W/ ASSOCIATED POINT LOADS @ TIME OF AWARD

ALL PLATFORMS / LANDINGS, GUARD RAILS, HAND RAILS, AND POSTS
AS REQUIRED ARE TO BE BY BLEACHERS INTERNATIONAL AT THE SITE.

BUILDING INSTALLATION IS BY BLEACHERS INTERNATIONAL AT THE SITE.